ATTAR TEST REPORT NUMBER: 14/8507.6



10 December 2014

Total Pages: 2 Job No: M14/8507

WET PENDULUM SLIP RESISTANCE

Prepared for:	Premium Floors Australia					
	7/14 Rodborough Road					
	FRENCH'S FOREST NSW 2086					
Attention:	Kendall Waller					
Test Site:	Test Slip Australia Pty Ltd, Beaumont Hills, NSW.					
Test Date:	8 December 2014					
Test Specimens, Size & Quantity:	ReadyCork Vita, 195x830 mm, 5 off supplied.					
Sampling & Direction of Testing:	Sampling conducted by client. Test direction parallel with grain of timber.					
Test Personnel:	Clark Aheam					
Preparation:	Washed with water and pH neutral detergent, rinsed					
_	with water, then dried.					
Fixed/Unfixed:	Unfixed.					
Air Temperature:	22°C					
Test Equipment:	Wessex Skid Resistance Tester (Pendulum) Serial					
	Number SK 1818, Calibrated 29/07/2014.					
Test Standard:	AS 4586: 2013 Slip resistance classification of new					
	pedestria	dix A.				
Slider Rubber:	Slider 96 Batch No. #55 prepared on P400 & 3µm					
	lapping film.					
Classification Criteria:	Refer to Classification Criteria, attached as Appendix 1.					
	Specimen Number					CDV/
British Pendulum Number	1	2	3	4	5	SRV
	30	30	32	31	30	31
Classification:	P2					

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance procedures and wear on their slip-resistance be

checked.

NOTE: Any specimens supplied will be disposed of in two (2) months time, unless otherwise instructed.

ATTAR

Marcus Braché

Senior Engineering Technician

Approved Signatory

This report may not be reproduced except in its entirety.

Page 1 of 2